

Date:- 12.06.2018



Name of Work:- Supply and Installation works (including Fabrication) of Signage and Graphics including all transportation, Loading and unloading etc., for 7 Metro Stations viz. Airport, Ujjwal Nagar, Jai Prakash Nagar, Chhatrapati Sq., Ajni Sq., Rahate Colony and Congress Nagar for Nagpur Metro Rail Project.


Tender No:- N1-MISC-19/2018

### Corrigendum - I

#### Part-A Bidders queries reply

Sr.No.	Document Name	Reference	Page No	Specification	Query/Clarification Required	Reply
1	Tender Documents	Forms of Tenders	General	Material specification Document	We have successfully downloaded all the documents which were uploaded in the E- Tender Portal, on going through the documents; we found that the technical material specification document is missing.	Technical Specification is uploaded with this corrigendum.
2	Notice Inviting Tender	Tender Security	Page 2 of Technical Package	Tender Security Amount	We are registered under MSME and NSIC, as it is a Government Project are we exempted from paying Tender Security Amount, kindly confirm.	Cannot be acceded to. Tender condition prevails.
3	Technical Package	Forms of Tenders	General		We are a Bangalore based company, is it necessary that, we need to establish a Branch office in Nagpur.	As per form 3 letter of undertaking, on award of work the bidder has to establish his office in Nagpur for better coordination.
4	Forms of Eids/Single stage	FORM - 5	Page No - 22	Audited Balance Sheet	Is it mandatory to upload the entire pages of audited Balance Sheet which comprises of more than 100 sheets or only the P&L sheet & Balance sheetschedule can be uploaded of the requested years?	Cannot be acceded to. Tender condition prevails. Audited balance sheet must be submitted.
5	Technical Package	Forms of Tenders	General	Online uploading of Documents	What is the maximum size of the document that can be uploaded on the portal	Single PDF size shall not be more than 10 MB and multiple such PDF can be uploaded.
6	PRICE BID	Bill of Quantities	01 of 47	Totalquantity	The quantity mentioned in the BOQ is for one station or applies to all the seven stations.	Quantities are for 7 stations





7	Technical Package	Payments	73	Statutory Deductions	Are there any tax Statutory deduction on our invoice during settlement of Payments, if any kindly mention.	IT, TDS, Labour cess and any other levy as applicable at the time of payment as per prevailing rules.
8	Technical Package	Special conditions of contract	111	Invoice Template	Kindly share the invoice pattern to be followed by the vendor.	As per GST law as per prevailing rules.
9	Bill of Quantities – Sign type - 1.1.1	Suspended Sign, illuminated, 2 sided - Single height	01 of 47	Boq Sl. No 01, Suspender, Drawing number TENM-R1-S&G-1-STD-1.1.1-P-1/2 & 2/2	In BOQ, it is specified to use LED STRIPS for Proper Illumination and in fabrication drawing it is mentioned to use POWER LED's 1.44V, kindly confirm whether we can use LED Edge Lit Modules instead of STRIP and also kindly confirm the Make.	Cannot be acceded to. Tender condition prevails
10	Bill of Quantities – Sign type - 1.1.1	Suspended Sign, illuminated, 2 sided - Single height	01 of 47	Boq Sl. No 01, Suspender, Drawing number TENM-R1-S&G-1-STD-1.1.1-P-1/2 & 2/2	In Fabrication Drawing (DETAIL b) whether the entire sign cabinet to be fabricated using Aluminium Profile or the curved area along can it be fabricated using aluminium Sheet bend to the shape.	Curved area along cannot be fabricated using aluminium sheet bend to the shape. In fabrication drawing (Detail b) entire sign cabinet must be fabricated using aluminium profile.
11	Bill of Quantities – Sign type - 1.1.1	Suspended Sign, illuminated, 2 sided - Single height	01 of 47	Boq Sl. No 01, Suspender, Drawing number TENM-R1-S&G-1-STD-1.1.1-P-1/2 & 2/2	Signage size mentioned in fabrication drawing is 300mm x 600mm outer to outer, at the same time even graphics size mentioned as 300mm x 600mm, in this case there will aluminium profile overlap on the graphics of 10mm, kindly confirm.	Yes, It will overlap.
12	Bill of Quantities – Sign type - 1.1.3/1.1.4	Face Mounted Sign illuminated	03 of 47	Drawing number TENM-R1-S&G-1-STD-1.1.3-P-1/2 & 2/2	In BOQ it is mentioned as 75mm deep shall be fabricated using 2mm thick aluminium extrusion channel, but in the Fabrication drawing it is shown as 85mm depth, kindly confirm whether to follow BOQ or Fabrication Drawings	75mm mentioned in BOQ stands corrected and should be read as 85mm.
13	Bill of Quantities – Sign type - 1.1.8	Post Mounted Sign, Non illuminated, 2 Sided	06 of 47	Drawing number TENM-R1-S&G-1-STD-1.1.8-P-1/3,2/3,3/3	In BOQ it is mentioned as 240mm deep shall be fabricated using 2mm thick aluminium extrusion channel, but in the Fabrication drawing it is shown as 260mm depth, kindly confirm whether to follow BOQ or Fabrication Drawings	240mm mentioned in BOQ stands corrected and should be read as 260mm.
14	Bill of Quantities – Sign type - 1.1.5a/2.4/2.1.6a/	Post Mounted Sign, non illuminated, 2 Sided	06 of 47	Drawing number TENM-R1-S&G-1-STD-1.1.8-P-1/3,2/3,3/3	It is being mentioned to use 80mm dia NB 2mm thick SS 316 grade hollow section, instead of SS, can we use MS hollow section.	Cannot be acceded to. Tender condition prevails.



15	Bill of Quantities – Sign type - 2.3.1	Face Mounted Sign, (Illuminated at back of the Logo)	10 of 47	Drawing number TENM-R1-S&G-1-STD-2.3.1-P-1/5 to 4/5	Kindly confirm the face material to be used, is it Direct Marble or Marble textured ACP.	The face material to be used is textured ACP.
16	Bill of Quantities – Sign type - 2.1.7	Post Mounted sign, Non illuminated Single side	17 of 47	Drawing number TENM-R1-S&G-1-STD-2.1.7-P-1/4 to 4/4	In BOQ it is mentioned as 75mm deep shall be fabricated using 2mm thick aluminium extrusion channel, but in the Fabrication drawing it shown as 90mm depth, kindly confirm whether to follow BOQ or Fabrication Drawings	75mm mentioned in BOQ stands corrected and should be read as 90mm.
17	Bill of Quantities – Sign type - 4.1	Suspended Sign, illuminated, 2 sided - Single height	37 of 47	Boq Sl. No 70, Suspender, Drawing number TENM-R1-S&G-1-STD-4.1-P-1/2 & 2/2	Specify the vinyl make and code to be used	Please refer Technical Specification Document.
18	Bill of Quantities – Sign type - 4.1	Suspended Sign, illuminated, 2 sided - Single height	37 of 47	Boq Sl. No 70, Suspender, Drawing number TENM-R1-S&G-1-STD-4.1-P-1/2 & 2/2	1) Is it a fully illuminated sign or only the Pictogram to be illuminated, kindly confirm. b) In case If it is fully illuminated, kindly the placement of LED DRIVER.	Entire Signage is fully illuminated. Driver can be kept at Centre of the Box, to avoid the Shadow.
19	Bill of Quantities	Suspended Sign Fixing	46 of 47	Boq Sl. No 121, Suspender, Drawing number TENM-R1-S&G-1.1.1/1.1.2/2.1.1/3.3.1-P/1	In Fabrication Drawing DETAIL D – it is shown as telescopic joint fixing of 75 Dia Pipe with 50mm Dia pipe at the same time in the TYPICAL DEETAIL “D” Drawing it is explained to joined both the pipes using plate fixing mechanism, kindly confirm	Plate Fixing mechanism shall be used.
20	Bill of Quantities	Suspended Sign Fixing	46 of 47	Boq Sl. No 121, Suspender, Drawing number TENM-R1-S&G-1.1.1/1.1.2/2.1.1/3.3.1-P/1	Kindly share a template with regards to suspender invoicing Methodology.	No Specific format. The variation quantity should be submitted in Excel sheet with covering letter to Maha-Metro.
21					Detailed drawing for suspender Section required . Height of suspender not mentioned in tender	Rate provided is for Total 2 meters.
22					Brands and detailed specifications are required ( not available in tender).such as LED , Vinyl , Arcrylic sheet / Mild Steel / ACM /overlay laminate film /Black Out Vinyl etc	Technical Specification is uploaded with this corrigendum.
23	Technical package	Sedction -5: Contract Data	28	Form-11 Details of Machinery and Equipment expected to be deployed		Corrected Form 11 is uploaded with this corrigendum.

**Corrigendum-I  
Part B  
Addendum**

Sr.No	Reference	Clause as in tender	Ammended
1	Cl. 27.2 ,Section 2: Instruction to bidders/Single stage Pg. no. 10	The Employer has the right to review at any time prior to award of contract that the qualification criteria as specified in the tender document are still being met by the Bidder whose offer has been determined to be the lowest evaluated tender. A tender shall be rejected, if the qualification criteria as specified in the tender document are no longer met by the Bidder whose offer has been determined to be the lowest evaluated tender. In this event, the Employer may proceed to the next lowest evaluated tender to make a similar reassessment of that Bidder's capabilities to perform satisfactorily, if the employer so desires.	The Employer has the right to review at any time prior to award of contract that the qualification criteria as specified in the tender document are still being met by the Bidder whose offer has been determined to be the lowest evaluated tender and maha-metro reserves the right to inspect sinages sample and manufacturing factory premises before award of contract.A tender shall be rejected, if the qualification criteria as specified in the tender document are no longer met by the Bidder whose offer has been determined to be the lowest evaluated tender and it may also rejected if the sinage sample and Manufacturing premises are not found to be as per requirement of Maha-Metro.In this event, the Employer may proceed to the next lowest evaluated tender to make a similar reassessment of that Bidder's capabilities to perform satisfactorily, if the employer so desires.



*[Signature]*  
**GM (Procurement)  
Maha-Metro, Nagpur**